



GENERAL NOTES

1. Tank is fabricated and labeled per UL-142.
2. Material is A-36 carbon steel.
3. Tank is tested in the shop per UL-142. Retesting by the customer at the jobsite is required.
4. Prime painted (gray).

INNER VENT CAP.	OUTER VENT CAP	DESCRIPTION	OVERALL SIZE	SHIP WT.
51,800 cfh	n/a	300 gallon Tank & Containment Dike	72" x 54" x 25"	965#
CUSTOMER NAME		APPROVED BY: _____ DATE: _____		



DRAWN BY: GFS	DATE DRAWN: 4/23/08
DWG NUMBER: 2250-00300	SCALE: 1:30
REV: _____	REV BY: _____
DATE: _____	SHEET: _____