



- GENERAL NOTES**
1. Tank is fabricated and labeled per UL-142.
  2. Dike provides 110% secondary containment.
  3. Material is A-36 carbon steel.
  4. Tank is tested in the shop per UL-142. Retesting by the customer at the jobsite is required.
  5. Tank and dike are sandblasted and painted (white epoxy).

INNER VENT CAP.	OUTER VENT CAP	DESCRIPTION	OVERALL SIZE	SHIP WT.
75,400 cfh	n/a	500 gallon UL-142 single wall tank & dike	72" x 96" x 59"	1605#

CUSTOMER NAME

APPROVED BY:

DATE:



DRAWN BY: GFS

DATE DRAWN: 5/1/08

DWG NUMBER: 225000500

SCALE: 1:30

REV:

REV BY:

DATE:

SHEET: