



- GENERAL NOTES**
1. Tank is fabricated and labeled per UL-142.
  2. Dike provides 110% secondary containment.
  3. Material is A-36 carbon steel.
  4. Tank is tested in the shop per UL-142. Retesting by the customer at the jobsite is required.
  5. Tank and dike are prime painted (gray).

INNER VENT CAP.	OUTER VENT CAP	DESCRIPTION	OVERALL SIZE	SHIP WT.
132,600 cfh	n/a	1000 gallon UL-142 single wall tank & dike	72" x 168" x 59"	2825#

CUSTOMER NAME		<b>APPROVED</b> BY:		DATE:
---------------	--	---------------------	--	-------



DRAWN BY: GFS	DATE DRAWN: 8/29/07
DWG NUMBER: 225001000	SCALE: 1:30
REV: _____	REV BY: _____
DATE: _____	SHEET: _____