



GENERAL NOTES:  
 1. TANK IS TO BE DESIGNED, FABRICATED AND STAMPED PER UL-142.

2. TANK AND DIKE TO BE PRIME PAINTED.

3. MATERIAL: A36 CARBON STEEL.

4. TANK IS LAP WELDED CONSTRUCTION.

5. DIKE PROVIDES 110% SECONDARY CONTAINMENT.

6. TANK IS PNEUMATICALLY TESTED TO 5 psi IN THE SHOP. RE-TESTING AT THE JOB SITE BY THE CUSTOMER IS REQUIRED.

INNER VENT CAP.	OUTER VENT CAP	DESCRIPTION	OVERALL SIZE	SHIP WT.
244,500 cfh	n/a	3000 gallon Single Wall Tank & Dike	8' x 22' x 6'	6000#

CUSTOMER NAME	APPROVED BY:	DATE:
---------------	--------------	-------

DRAWN BY: GFS	DATE DRAWN: 9/23/08
DWG NUMBER: 2650-03000	SCALE: none
REV: _____	REV BY: _____
_____	DATE: _____
_____	SHEET: _____